



Legend

Fire Flow Requirement	Toll Tap	Transmission Mains	Water Main by Diameter	Pressure Zones (HGL) 260	460	585
1000 gpm	Emergency Intertie	Toll Pipeline	6" and Smaller	305	485	650
2500 gpm	Pump Station	Major Highways	8" - 12"	350	510	670
3500 gpm	Storage Facility	Parcels	14" and Larger	420	570	770
Closed Valves					WWD RSA	

FIRE FLOW REQUIREMENTS

FIGURE 5.5

WOODINVILLE WATER DISTRICT
COMPREHENSIVE WATER SYSTEM PLAN



Document Path: \\of-sal\Data\GIS\Backup\Woodinville\Maps\Figs_4_FireFlow.mxd

