


NOTES:

1. 4" PVC DRAIN TO PARALLEL WATERLINE W/ OFFSET BETWEEN PIPES DETERMINED BY THE ENGINEER.
2. PAVEMENT RESTORATION PER CONTRACT DOCUMENTS.
3. GEO TEXTILE FABRIC TO BE WATER PERMEABLE.

TRENCH DAM DETAIL



**Woodinville
Water District**

**TRENCH DAM
DETAIL**



**WATER STD.
PLAN NO. 27**

**REVISION DATE
12-16**