


SECTION

NOTES:

1. NOTIFY THE DISTRICT AT LEAST 7 DAYS IN ADVANCE AND MAKE THE NECESSARY ARRANGEMENTS WITH THE WATER DISTRICT INSPECTOR FOR CONNECTION TO THE EXISTING MANHOLE.
2. CONTRACTOR SHALL SUBMIT A BYPASS PLAN FOR EXISTING FLOWS WHILE WORKING IN THE EXISTING MANHOLE UNLESS DEEMED UNNECESSARY BY THE DISTRICT.
3. ROTATE CONE AND INSTALL NEW LADDER PER STANDARD DETAIL 18 IF EXISTING LADDER IS WITHIN 6" OF THE EDGE OF ANY CHANNEL.
4. CORE EXISTING MH AND USE KOR-N-SEAL CONNECTION, UNLESS KNOCKOUTS EXIST ON THE BASE SECTION. IN THIS CASE, CORE STILL REQUIRED AND GPK SAND COLLAR SHALL BE USED INSTEAD OF THE KOR-N-SEAL BOOT.
5. CONNECTIONS INTO AN EXISTING FIBERGLASS BASE, CONTRACTOR SHALL REPLACE THE BASE SECTION OR HAVE THE CHANNEL RE-GLASS BY A CERTIFIED SERVICE TECHNICIAN TO ACCOMMODATE THE NEW CONNECTION. (WWW.PREDLSYSTEMS.COM) FOR A LIST OF CERTIFIED TECHNICIANS THAT CAN PERFORM THE WORK.



**Woodinville
Water District**

**CONNECTION TO
EXISTING MH**



**SEWER STD.
PLAN NO. 1**

REVISION DATE

12-20