



SEE STANDARD PLAN 13M FOR MATERIAL LIST  
 NOTE - CIRCLED NUMBERS ABOVE REFER TO MATERIALS LISTED ON STD PLAN 13M.

NOTES:

1. CONTRACTOR TO PROVIDE ALL MATERIALS. SERVICES SHALL BE TESTED WITH THE MAINLINE.
2. TRACE WIRES MUST BE VISIBLE IN METER BOX.
3. NO SPLICES ALLOWED IN SERVICE LINE.
4. CORP STOP LOCATION SHALL BE OFFSET PRECISELY FOR GPS SURVEY.
5. LOCATE METER BOX OUT OF PAVING OR SIDEWALKS. METER BOX SHALL BE PERPENDICULAR TO THE SIDEWALK OR AS DIRECTED BY THE DISTRICT.
6. CONTRACTOR SHALL SCHEDULE SERVICE FLUSH WITH THE DISTRICT'S INSPECTOR.
7. METER INSTALLATION BY THE DISTRICT. METER WILL NOT BE SET UNTIL PROJECT ACCEPTED.
8. THE BACKSIDE OF ALL SERVICES SHALL BE PLUMBED IN TYPE "K" COPPER AND HAVE BACKFLOW PROTECTION. DOMESTIC WATER SHALL CONNECT TO A RPBA PER STD. PLAN 19. IRRIGATION AND FIRE METERS SHALL CONNECT TO A DCVA PER STD PLAN 21.
9. IF FIRE OR IRRIGATION SERVICE IS REQUIRED, IT SHALL BE A SEPARATE DEDICATED SERVICE. FIRE SERVICE SHALL BE SIZED ACCORDING TO FLOW REQUIREMENTS NEEDED.

NOTE: ALL BRASS COMPONENTS SHALL CONFORM TO THE LATEST VERSIONS OF NSF 61 AND ANSI/AWWA STANDARD C800 AND SHALL BE STAMPED/ EMOSSSED TO SHOW THE PRODUCT IS MADE FROM A NO LEAD ALLOY.



**Woodinville  
Water District**

**1" COMMERCIAL  
SERVICE CONNECTION**



**WATER STD.  
PLAN NO. 16**

REVISION DATE  
11-13