



**NOTES:**

1. MAX BURY DEPTH FOR FIRE HYDRANTS SHALL BE 6'. FOR DEEPER INSTALLATIONS INSTALL A 4' BURY FIRE HYDRANT WITH A VERTICAL BENDS AS SHOWN. 45° MAXIMUM VERTICAL BEND.
2. INSTALL GRAVITY BLOCKING PER STANDARD PLAN NO. 4.
3. SEE STANDARD PLANS 9A AND STANDARD SPECIFICATIONS FOR NEW HYDRANT INSTALLATION REQUIREMENTS.



**Woodinville  
Water District**

**DEEP FIRE  
HYDRANT INSTALLATION**



**WATER STD.  
PLAN NO. 9C**

REVISION DATE  
12-20