


NOTES:

1. IT SHALL BE THE OWNER'S RESPONSIBILITY TO INSURE THAT THE SERVICE LINES AND METER SIZES ARE ADEQUATE TO SERVE THE DOMESTIC & FIRE SPRINKLER OR IRRIGATION SYSTEMS. REFER TO LARGER METER AND BACKFLOW DETAILS FOR SYSTEMS REQUIRING PIPE AND METER LARGER THAN 1".
2. INSTALL DUAL SERVICE IN ACCORDANCE WITH STANDARD PLAN 13 & 13M. BACK OF METER BOX SHALL BE PLACED AT THE R/W LINE OR IN THE WATER EASEMENT IF SIDEWALK AT EDGE OF R/W.
3. THE BACKFLOW PREVENTION DEVICE SHALL BE A DOUBLE CHECK ASSEMBLY AS APPROVED BY THE WASHINGTON STATE DEPARTMENT OF HEALTH. MIN. SIZE OF BACKFLOW DEVICE SHALL MATCH METER SIZE.
4. NO CHEMICALS ARE ALLOWED IN THE FIRE SPRINKLER PIPING SYSTEM.
5. FIRE SPRINKLER SYSTEMS SHALL BE DESIGNED IN ACCORDANCE WITH THE LOCAL FIRE MARSHAL'S REQUIREMENTS AND HAVE FIRE MARSHALL APPROVAL.
6. NO METER OR DCVA BOXES ALLOWED IN DRIVEWAYS OR HARD SURFACED AREAS.
7. INSPECTION REQUIRED ON FIRE SERVICE AND BACKFLOW ASSEMBLY PRIOR TO BACKFILL. CALL 425-487-4100 TO SCHEDULE.



**Woodinville
Water District**

**1" SINGLE FAMILY DUAL
PURPOSE DOMESTIC AND
FIRE SERVICE
CONNECTION**



**WATER STD.
PLAN NO. 14B**

**REVISION DATE
3-18**