



**NOTES:**

1. HILLHOLDER PIPE ANCHORS REQUIRED ON SLOPES MORE THAN 20%.
2. SPACING AS APPROVED BY THE DISTRICT'S ENGINEER.
3. RESTRAINED JOINS REQUIRED ON WATERLINE.
4. LOCATE PIPE ANCHOR/ SLOPE RETAINER ON DOWN HILL SIDE OF PIPE BELL WHEN PRACTICAL.



**Woodinville  
Water District**

**PIPE ANCHOR /  
SLOPE RETAINER**



**WATER STD.  
PLAN NO. 5**

**REVISION DATE  
12-20**