


**NOTES:**

1. HILLHOLDER PIPE ANCHORS REQUIRED ON SLOPES MORE THAN 20%.
2. SPACING AS APPROVED BY THE DISTRICT'S ENGINEER.
3. DUCTILE IRON PIPE REQUIRED ON SLOPES OVER 20%.
4. LOCATE PIPE ANCHOR / SLOPE RETAINER ON DOWN HILL SIDE OF PIPE BELL WHEN PRACTICAL.



Woodinville  
Water District

CONCRETE ANCHOR  
FOR SEWER MAINS  
IN STEEP SLOPES



SEWER STD.  
PLAN NO. (12)

REVISION DATE  
04/25