


NOTES:

1. AFTER THE BYPASS PLAN (IF APPLICABLE) HAS BEEN APPROVED BY THE DISTRICT, SEVEN (7) DAYS WRITTEN NOTICE IS REQUIRED PRIOR TO CONNECTION TO THE EXISTING SEWER SYSTEM.
2. EXISTING SEWER FLOWS SHALL NOT BE INTERRUPTED. CONTRACTOR SHALL BE RESPONSIBLE FOR ALL EQUIPMENT AND COSTS NECESSARY TO BYPASS EXISTING FLOWS.
3. ALL APPLICABLE DETAILS FROM SEWER STANDARD PLAN 15 (STANDARD SIDE SEWER INSTALLATION) APPLY TO CUT-IN SIDE SEWER.
4. COMMERCIAL SIDE SEWERS SHALL CONNECT TO A NEW FIBERGLASS REINFORCED OR POLYPROPYLENE BASE LINER OR APPROVED EQUAL MANHOLE BASE. ALL APPLICABLE DETAILS FROM SEWER STANDARD PLAN 4 (ALTERNATIVE SADDLE MH DETAIL) APPLY TO COMMERCIAL CUT-INS.



Woodinville  
Water District

SIDE SEWER INSTALLATION  
ON EXISTING MAIN



SEWER STD.  
PLAN NO. 17

REVISION DATE  
04/25