


NOTES:

1. HILLHOLDER PIPE ANCHORS REQUIRED ON SLOPES MORE THAN 20% OR AS DIRECTED BY THE DISTRICT.
2. SPACING AS APPROVED BY THE DISTRICT'S ENGINEER.
3. RESTRAINED JOINTS REQUIRED ON WATERLINE.
4. LOCATE PIPE ANCHOR/ SLOPE RETAINER ON DOWN HILL SIDE OF PIPE BELL WHEN PRACTICAL.



Woodinville
Water District

PIPE ANCHOR /
SLOPE RETAINER



WATER STD.
PLAN NO. **5**

REVISION DATE
04/25