


**NOTES:**

1. MAX BURY DEPTH FOR FIRE HYDRANTS SHALL BE 6'. FOR DEEPER INSTALLATIONS INSTALL A 4' BURY FIRE HYDRANT WITH A VERTICAL BENDS AS SHOWN. 45° MAXIMUM VERTICAL BEND.
2. INSTALL GRAVITY BLOCKING PER STANDARD PLAN NO. 4.
3. ALL APPLICABLE DETAILS FROM STANDARD PLANS 9, 9A, 9C, AND STANDARD SPECIFICATIONS FOR NEW HYDRANT INSTALLATION REQUIREMENTS APPLY TO DEEP FIRE HYDRANT INSTALLATIONS.



**Woodinville  
Water District**

**DEEP FIRE  
HYDRANT INSTALLATION**



**WATER STD.  
PLAN NO. 9B**

REVISION DATE  
**04/25**