


**NOTES:**

1. ALL APPLICABLE DETAILS FROM STANDARD PLANS 9, 9A, AND 9B APPLY TO RELOCATED FIRE HYDRANT.
2. EXISTING FIRE HYDRANT MUST BE PRESSURE TESTED PRIOR TO RELOCATION AND RETESTED PRIOR TO ACCEPTANCE.
3. REPLACE 6" EXISTING PIPE BACK TO FOOT VALVE. ALL MECHANICAL JOINTS SHALL BE MEG -A-LUG OR EQUAL. REPLACE EXISTING GATE VALVE IF IT IS A DOUBLE DISC OR DOES NOT CONFORM TO AWWA C509 OR C515 OR IS NOT AN APPROVED GATE VALVE FOR THE DISTRICT (SEE MW-3 IN STANDARD SPECIFICATIONS)
4. REPLACE VALVE BOX PER STANDARD PLAN NO. 6.
5. THE CONTRACTOR SHALL BE RESPONSIBLE TO PROVIDE AND INSTALL A FH BARREL EXTENSION, IF NECESSARY, TO COMPLY WITH THE CLEARANCES SHOWN ABOVE.
6. INSTALL A NEW FIRE HYDRANT PER STANDARD PLANS 9 OR 9B & 9A UNLESS THE EXISTING FIRE HYDRANT MEETS CURRENT DISTRICT STANDARDS FOR NEW FIRE HYDRANTS (SEE MW-9A IN THE STANDARD SPECIFICATIONS).
7. RELOCATED FIRE HYDRANTS SHALL BE PAINTED AND LETTERED PER THE SPECIFICATIONS. RE-USED FIRE HYDRANTS SHALL BE PRESSURE WASHED (MIN. 3000PSI) PRIOR TO PAINTING.
8. INSTALL STORZ ADAPTER PER WOODINVILLE, BOTHELL, REDMOND, AND KIRKLAND FIRE STANDARD PLANS.



**Woodinville  
Water District**

**RELOCATE EXISTING  
FIRE HYDRANT**



**WATER STD.  
PLAN NO. 9C**

REVISION DATE  
04/25