


**NOTES:**

1. ALL NOTES FROM WATER STANDARD PLAN 19 APPLY TO THIS DETAIL.
2. RPBA/RPDA MUST CONNECT IMMEDIATELY ADJACENT TO WATER METER.
3. 120V ELECTRICAL GFCI OUTLET FOR HEAT TAPE REQUIRED. INSTALL AWAY FROM RPBA/RPDA DISCHARGE. INSTALL HEAT TAPE FOR FREEZE PROTECTION.
4. ALL FITTINGS AND BRASS COMPONENTS SHALL CONFORM TO THE LATEST VERSION OF NSF 61 AND ANSI/AWWA STANDARD C800 AND SHALL BE STAMPED/EMBOSSED TO SHOW THE PRODUCT IS MADE FROM A NO LEAD ALLOY.



**Woodinville  
Water District**

**2" AND SMALLER  
REDUCED PRESSURE  
BACKFLOW ASSEMBLY**



**WATER STD.  
PLAN NO. 19A**

REVISION DATE  
**04/25**

EXPIRES: 11/21/2026